


ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 0846/14.04.2020

Performance list, acc. to EN 54-7:2000, EN 54-7:2000/A1:2002, EN 54-7:2000/A2:2006

Essential Characteristics	Performance	Clause
Nominal activation conditions / sensitivity / response delay (response time) and performance under fire conditions		
- Response to slowly developing fires	N/A	4.8
- Repeatability	pass	5.2
- Directional dependence	pass	5.3
- Reproducibility	pass	5.4
- Air movement	pass	5.6
- Dazzling	pass	5.7
- Fire sensitivity	pass	5.18
Operational reliability		
- Individual alarm indication	pass	4.2
- Connection of ancillary devices	pass	4.3
- Monitoring of detachable detectors	pass	4.4
- Manufacturer's adjustments	pass	4.5
- On-site adjustment of response behaviour	N/A	4.6
- Protection against the ingress of foreign bodies	pass	4.7
- Marking	pass	4.9
- Data	pass	4.10
- Additional requirements for software controlled detectors	pass	4.11
Tolerance to supply voltage	pass	5.5
Durability of operational reliability and response delay, temperature resistance		
- Dry heat (operational)	pass	5.8
- Cold (operational)	pass	5.9
Durability of operational reliability, vibration resistance		
- Shock (operational)	pass	5.13
- Impact (operational)	pass	5.14
- Vibration, sinusoidal (operational)	pass	5.15
- Vibration, sinusoidal (endurance)	pass	5.16
Durability of operational reliability, humidity resistance		
- Damp heat (operational)	pass	5.10
- Damp heat, steady state (endurance)	pass	5.11
Durability of operational reliability, corrosion resistance	pass	5.12
Durability of operational reliability, electrical stability		
- Electromagnetic compatibility (EMC), immunity (operational)	pass	5.17



Manager:



dipl.eng. Anna Vasileva

Issued:
Burgas, 14 April 2020