

## ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 0943/14.04.2020

Performance list, acc. to EN 54-11:2001; EN 54-11:2001/A1:2005

Characteristics	Compliance	Clause
<b>Nominal activation conditions / Sensitivity and Performance under fire conditions</b>		
- Alarm condition	Pass	4.3.2
- Indicators for alarm condition	Pass	4.4
- Safety aspects	Pass	4.7.1
- Protection against accidental operation	Pass	4.7.4
- Operational performance test	Pass	5.2
- Function test	Pass	5.3
<b>Operational reliability</b>		
- Marking and data	Pass	4.2
- Normal condition	Pass	4.3.1
- Reset facility	Pass	4.5
- Test facility	Pass	4.6
- Shape, dimensions and colours	Pass	4.7.2
- Symbols and lettering	Pass	4.7.3
- Environment category	Pass	4.7.5
- Additional requirements for software controlled manual call points	N/A	4.8
- Test facility test (operational)	Pass	5.4
- Reliability test (endurance)	Pass	5.5
<b>Durability of operational reliability, temperature resistance</b>		
- Dry heat (operational)	Pass	5.7
- Dry heat (endurance)	N/A	5.8
- Cold (operational)	Pass	5.9
<b>Durability of operational reliability, vibration resistance</b>		
- Shock (operational)	Pass	5.14
- Impact (operational)	Pass	5.15
- Vibration, sinusoidal (operational)	Pass	5.16
- Vibration, sinusoidal (endurance)	Pass	5.17
<b>Durability of operational reliability, humidity resistance</b>		
- Damp heat, cyclic (operational)	Pass	5.10
- Damp heat, cyclic (endurance)	N/A	5.11
- Damp heat, steady state (endurance)	Pass	5.12
- Enclosure protection	N/A	5.19
<b>Durability of operational reliability, corrosion resistance</b>		
- Damp heat, cyclic (endurance)	N/A	5.11
- Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	Pass	5.13
<b>Durability of operational reliability, electrical stability</b>		
- Variation of supply parameters	Pass	5.6
- Electromagnetic compatibility (EMC) (operational)	N/A	5.18



Embossed stamp of "Dedal - A&C" Ltd.

Manager:



dipl.eng. Anna Vasileva

