

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1273/14.04.2020, (page 2/2)

Performance list, acc. to EN 54-5:2000, EN 54-5:2000/A1:2002

Addressable heat detector D9000AI T A1S; Addressable heat detector D9000A T A1S

Essential Characteristics	Performance	Clause
Nominal activation conditions / sensitivity / response delay (response time) and performance under fire conditions		
- Classification	Pass, A1S	4.2
- Position of heat sensitive element	Pass	4.3
- Directional dependence	Pass	5.2
- Static response temperature	Pass	5.3
- Response times from typical application temperature	Pass	5.4
- Response times from 25 °C	N/A	5.5
- Response times from high ambient temperature	Pass	5.6
- Reproducibility	Pass	5.8
- Additional test for suffix S detectors	Pass	6.1
- Additional test for suffix R detectors	N/A	6.2
Operational reliability		
- Individual alarm indication	Pass	4.4
- Connection of ancillary devices	Pass	4.5
- Monitoring of detachable detectors	Pass	4.6
- Manufacturer's adjustments	Pass	4.7
- On-site adjustment of response behaviour	Pass	4.8
- Marking	Pass	4.9
- Data	Pass	4.10
- Additional requirements for software controlled detectors	Pass	4.11
Tolerance to supply voltage		
- Variation in supply parameters	Pass	5.7
Durability of operational reliability and response delay, temperature resistance		
- Cold (operational)	Pass	5.9
- Dry heat (endurance)	N/A	5.10
Durability of operational reliability, vibration resistance		
- Shock (operational)	NPD	5.14
- Impact (operational)	Pass	5.15
- Vibration, sinusoidal (operational)	Pass	5.16
- Vibration, sinusoidal (endurance)	Pass	5.17
Durability of operational reliability, humidity resistance		
- Damp heat, cyclic (operational)	Pass	5.11
- Damp heat, steady state (endurance)	Pass	5.12
Durability of operational reliability, corrosion resistance		
- Sulphur dioxide (SO ₂) corrosion (endurance)	NPD	5.13
Durability of operational reliability, electrical stability		
- Electromagnetic compatibility (EMC), immunity (operational)	Pass	15.8



Embossed stamp of "Dedal - A&C" Ltd.



Anna Vasileva

Manager:



dipl. eng. Anna Vasileva